

May 13, 2015

## **Addendum 2**

Notice to all holders of Bid Documents for **Bureau of Motor Vehicles Parking Lot Improvements, 101 Hospital St., Augusta, Maine – BGS# 1994**

The following changes are to be incorporated into the Contract Documents for Bureau of Motor Vehicles Parking Lot Improvements, 101 Hospital Street, Augusta, Maine:

1. The concrete curb detail, and the sidewalk with curb detail, shown on sheet 2 of the plan set has been drafted as a precast concrete curb unit. It is acceptable to create this same concrete curb (with a 6" reveal to pavement) utilizing slip form construction techniques for concrete curb. The curb must be buried in the ground as shown on the detail and not placed on the pavement.
2. Bid opening has been changed to Tuesday, May 19, 2015 at 2:00PM. The Contractor Bid Bond (section 00 43 13) has been incorrectly filled out with the wrong date. Please white out the 15<sup>th</sup> and insert the corrected date of May 19<sup>th</sup>.

Please remember to acknowledge addendum 1 dated May 11, 2015 and this addendum 2 dated May 13, 2015 in the Contractor Bid form (Section 00 41 13).